



### Description

The air release valves will be installed at sections of the pipeline where air pockets would be formed. The valves shall be of robust construction of double orifices with an integral isolating valve and flanged base for connection to a valve stem that connects the air valve to the main pipeline. The bore leading to the flange base shall be in accordance to the size of the main pipeline and the expected accumulation of air.

Working Pressure: 1.0MPa/ 1.6Mpa

Sizes: DN50-100